



JAS-ANZ



INDIAN ANALYTICAL LABORATORIES

A-11, Vidya Vihar, Pocket-A, Hastal Indl. Area, Uttam Nagar, New Delhi-59, Office Query No. +91-8755120033,9212366300-301 Tel. : 011-25352943, Telefax : 011- 25352943

Approval No. : 10/LAB/95

Govt. Approved Test House

GLP Approved Lab

FORM - 39 Report of Analysis



Submitted By M/s. New Age Public School (Recognised)
12, Gupta Enclave, Vikas Nagar Main Ranholla Road
New Delhi-110059, India

Report No. IAL/WT/201102001

Date of Receipt 02/11/2020

Your Ref. NS

Sample Name Water For Drinking Purpose

Mfg. By NS

Supplied By NS

Mfg. Lic. No. NS

Batch No.	Batch Size	Mfg.Date	Exp.Date	Sample Qty.:
NS	NS	N/A	N/A	1.0 L.

Reference to protocol
Description

IS-10500-2012
Colourless liquid

	OBTAINED	LIMITS	METHOD
Odour	Agreeable	Agreeable	IS:3025 (PART 5)-83
Taste	Agreeable	Agreeable	IS:3025 (PART 7)-84
Colour,Hazen Units	Colourless	NMT-5	IS:3025 (PART 4)-83
pH Value	7.5	6.5 to 8.5	IS:3025 (PART 11)-84
Total Dissolved Solids, mg/L	79	NMT-500	IS:3025 (PART 16)-84
Turbidity,NTU	Within limits	NMT-1	IS:3025 (PART 10)-84
Chloride as Cl, mg/L	20.0	NMT-250	IS:3025 (PART 32)-88
Calcium as Ca, mg/L	15.5	NMT-75	IS:3025 (PART 21)-09
Magnesium as Mg, mg/L	2.71	NMT-30	IS:3025 (PART 46)
Total Hardness as Ca CO3 mg/L	44.9	NMT-200	IS:3025 (PART 21)-09
Fluoride as F, mg/L,	Nil	NMT-1.0	IS:3025 (PART 60)
Bacteriological Tests			
Total coliform bacteria	Absent	Absent/100 mL Sample	IS:1622-1981 (2003)
E.Coli/100mL	Absent	Absent/100 mL Sample	IS:1622-1981 (2003)

09/11/2020

DATE OF COMPLETION

PERSON-IN-CHARGE



JAS-ANZ



INDIAN ANALYTICAL LABORATORIES

A-11, Vidya Vihar, Pocket-A, Hastal Indl. Area, Uttam Nagar,
New Delhi-59, Office Query No. +91-8755120033,9212366300-301
Tel. : 011-25352943, Telefax : 011- 25352943

Approval No. : 10/LAB/95

Govt. Approved Test House

GLP Approved Lab

FORM - 39 Report of Analysis



Submitted By M/s. New Age Public School (Recognised)
12, Gupta Enclave, Vikas Nagar Main Ranholla Road
New Delhi-110059, India

Report No. IAL/WT/201102001

Date of Receipt 02/11/2020

Your Ref. NS

Sample Name Water For Drinking Purpose


Mfg. By NS

Supplied By NS

Mfg. Lic. No. NS

Batch No.	Batch Size	Mfg.Date	Exp.Date	Sample Qty.:
NS	NS	N/A	N/A	1.0 L.

In the opinion of undersigned the sample referred to above is of standard quality as defined in the Act & rules for the reason given below.
Complies with the above respects.



09/11/2020

DATE OF COMPLETION

PERSON-IN-CHARGE